

TEST REPORT

Your ref.: 1232

Enquiries: A Van Der Walt

Tel.: 012 428-6007

Report No: 2538/0021/FHT15

Page: 1 of 7 Date: 2015-06-29

AAAMSA Attention: Mr H Schefferlie P.O. Box 7861 Halfway House 1685

FENESTRATION PRODUCTS – MECHANICAL PERFORMANCE CRITERIA SANS 613 : 2011

- 1 SIGNIFICANCE OF TEST RESULTS CONTAINED IN THIS REPORT
- 1.1 Refer to the print on the bottom of this page.
- 1.2 The sample described was tested for water tightness, deflection, structural strength, second water tightness, air tightness and operation of product requirements of SANS 613:2011 "Fenestration Products Mechanical Performance Criteria".
- 1.3 The sample tested complied with the requirements of SANS 613:2011 achieving a Class Designation of A5.
- 2 SAMPLE

2.1 SAMPLE DESCRIPTION

uPVC casement window. Dimensions of system being 1495 mm high by 2382 mm wide. Refer section 5, additional product information on page 4 and controlled dismantle findings.

The sample was supplied by the following applicant:

TEVA

Attention: Jacobus Malherbe 7 Trevallyn East River Road Kya Sands 2163

2.2 DATE OF RECEIPT

26 May 2015.

2.3 DATE TESTED

1 and 2 June 2015.

2.4 CONDITION OF SAMPLE

The sample was in suitable condition for testing purposes.

1 Dr Lategan Road, Groenkloof, Private Bag X191, Pretoria, 0001. Tel +27 12 428 7911. Fax +27 12 344 1568

SABS Commercial SOC Ltd conducted a conformity assessment pertaining to a sample of the product, commodity or system identified and the outcome recorded in this test report only relates to that specified sample. The conformity assessment outcomes recorded in the test report do not imply SABS Approval of the quality and/or performance of the sample(s) in question and the test results do not apply to any similar sample that has not been tested. (Refer also to the conditions of test printed on the back of this page.) This report may not be reproduced except in full. The authenticity of this report and its contents can be confirmed by contacting the person who signed it.